

**2024 Annual Performance Report Municipal Stormwater
Management System Environmental Compliance Approval
Number 243-S701 Schedule E Section 5.2 Report**

Township of East Garafraxa for the Period of January 1, 2024, to December 31, 2024



2024 Annual Performance Report
CLI – ECA # 243-S701 Schedule E Section 5.2 Report
Township of East Garafraxa

This annual report was prepared to satisfy the requirements of the Township of East Garafraxa's Consolidated Linear Infrastructure Environmental Compliance Approval number (CLI-ECA) 243-S701 for a Municipal Stormwater Management System. Issued by the Ministry of the Environment, Climate Change and Parks (MECP) on January 22, 2024

This is the first report required under the CLI-ECA and covers the calendar year of 2024

The reporting requirement for each section of the approval are listed below with the relevant information following the bolded text.

Section (5.2.1)

Submitted to the Director on or before April 30th of each year and covers the period from January 1st to December 31st of the preceding calendar year.

This report was submitted before April 30, 2025 and was for the period of January 1, 2024, to December 31, 2024.

Section (5.2.2)

Includes a summary of all monitoring data along with an interpretation of the data and an overview of the condition and operational performance of the Authorized System and any Adverse Effects on the Natural Environment.

This is a future requirement of the CLI-ECA and has not been put into practice at this time.

5.2.3 Includes a summary and interpretation of environmental trends based on all monitoring information and data for the previous five (5) years.

This is a future requirement of the CLI-ECA and has not been put into practice at this time.

5.2.4 Includes a summary of any operating problems encountered and corrective actions taken.

5.2.5 Includes a summary of all inspections, maintenance, and repairs carried out on any major structure, equipment, apparatus, mechanism, or thing forming part of the Authorized System.

2024 Annual Performance Report
CLI – ECA # 243-S701 Schedule E Section 5.2 Report
Township of East Garafraxa

Stormwater Management (SWM) ID # and name	Summary of Operation and Inspections Issues	Summary of Corrective Actions
12068 – Nature’s Landing Drive Subdivision Wet Pond	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12184 – Rayburn Meadows West-Dry Pond	Operational issues: Some vegetation growth with larger shrubs and small trees present Structural issues: no issues	Contractor removed small trees and shrubs in summer 2024
12183 – Rayburn Meadows East – Dry Pond	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12320 – Woodland Drive – Dry Pond No. 1	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12321 – Brookhaven Park – Dry Pond No. 2	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12234 – 37 Brookhaven Crescent – Dry Pond No. 3	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12259 – 2 Brookhaven Crescent – Dry Pond No. 4	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12323 – 44 Brookhaven Crescent – Dry Pond No. 5	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12303 – 57,59,61 Brookhaven Crescent – Dry Pond No. 6	Operational issues: Some vegetation growth, not excessive Structural issues: no issues	No corrective actions required
12322 – 12 Woodland Drive – Dry Pond No. 7	Operational issues: Some vegetation growth with larger shrubs and small trees present Structural issues: no issues	Contractor removed small trees and shrubs in summer 2024

5.2.6 Includes a summary of the calibration and maintenance carried out on all monitoring equipment.

There is no monitoring equipment installed at this time.

5.2.7 Includes a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.

There were no complaints received. No actions taken.

5.2.8 Includes a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.

There were no alterations to the system, therefore there were no significant drinking water threats.

5.2.9 Includes a summary of all spills or abnormal discharge events.

There were no spills of abnormal discharges.

5.2.10 Includes a summary of actions taken, including timelines, to improve or correct performance of any aspect of the Authorized System.

There are no actions required to be taken at this time.

5.2.11 Includes a summary of the status of actions for the previous reporting year.

This is the first reporting year, therefore there are no actions for the previous year.

5.3.1 Make available, on request and without charge, to members of the public who are served by the Authorized System.

This report is available to members of the public without charge by accessing the township website or contacting the township office.

5.3.2 Made available, by June 1st of the same reporting year, to members of the public without charge by publishing the report on the Internet, if the Owner maintains a website on the Internet.

The report will be made available to members of the public by June 1st by looking it up on the township website. <https://www.eastgarafraxa.ca/en/index.aspx>